



Eurofins KVI-PLUSZ
Környezetvédelmi Vizsgáló Iroda Kft.
1211 Budapest, Szállító u. 6.
Tel.: 261-2978, Fax: 261-4323

www.kviplusz.hu, info@kviplusz.hu

Evaluation summary of the testing reports of the environmental samples

Customer: **Dr. Schutz GmbH Alpár Jakab**

Sample was carried out on 01 August 2019. by Eurofins KVI PLUSz Ltd. (Accredited: NAH-1-1377/2015; NAH-1-1377/2019). Before sampling all surface samples were cleaned with 5%-os Haemasol solution.

Results

Names of samples	yeasts- and moduls colony count	total count	unit of measurement
Uncoated PVC horizontal surface I.	<5	<5	100cm ²
Uncoated PVC horizontal surface II.	<5	<5	100cm ²
Uncoated PVC without welding camber	<5	<5	100cm ²
Uncoated PVC welding I.	<5	1000	100cm ²
Uncoated PVC corner welding	<5	2000	100cm ²
Dr. Schutz PU Anticolor horizontal surface I.	<5	<5	100cm ²
Dr. Schutz PU Anticolor horizontal surface II.	<5	<5	100cm ²
Dr. Schutz PU Anticolor without welding camber	<5	<5	100cm ²
Dr. Schutz PU Anticolor welding I.	<5	<5	100cm ²
Dr. Schutz PU Anticolor corner welding	<5	<5	100cm ²
Dr. Schutz UV PU Sealer horizontal surface I.	<5	<5	100cm ²
Dr. Schutz UV PU Sealer horizontal surface II.	5	<5	100cm ²
Dr. Schutz UV PU Sealer without welding camber	<5	<5	100cm ²
Dr. Schutz UV PU Sealer welding I.	<5	<5	100cm ²
Dr. Schutz UV PU Sealer corner welding	5	<5	100cm ²

Results

Names of samples	total count	unit of measurement
Dr. Schutz PU Sealer horizontal surface I.	<5	100cm ²
Dr. Schutz PU horizontal surface II.	<5	100cm ²
Dr. Schutz PU Sealer without welding camber	<5	100cm ²
Dr. Schutz PU Sealer welding I.	<5	100cm ²
Dr. Schutz PU Sealer corner welding	<5	100cm ²

2020.01.16. Budapest


Lippai Anett
head of laboratory
Eurofins KVI-PLUSZ
Környezetvédelmi Vizsgáló Iroda Kft
Vizsgálólaboratórium
1211 Budapest, Szállító utca 6.